

Gas Leak Detection Testing

	Food Truck Name:	
DATE:	Employee Name:	PASS/FAIL

F-122.8.1 - A test gauge shall be installed at or before the regulator for means of leak detection.

Pressure shall be observed for a minimum of 3 minutes with no drop in pressure.

F-122.8.2 - LP-gas systems shall be inspected prior to each use and leak detection shall be performed every time a new connection or a change in cylinder is made to any gas system.