



# BROWARD COUNTY BOARD OF RULES AND APPEALS

1 N. University Drive, Suite 3500B  
Plantation, FL 33324

Phone: 954-765-4500  
Fax: 954-765-4504

[broward.org/CodeAppeals](http://broward.org/CodeAppeals)

## FBC 7<sup>th</sup> EDITION (2020) FORMAL INTERPRETATION (#24)

**DATE:** September 10, 2020  
**TO:** All Building Officials  
**FROM:** James DiPietro, Administrative Director  
**SUBJECT:** Retrofit of Windows, Doors, Garage Doors, Shutters and Skylights  
FBC Existing Building, Alteration Level I

### 2020 Voting Members

#### **Chair**

Mr. Daniel Lavrich,  
P.E., S.I., SECB, F.ASCE, F.SEI  
Structural Engineer

#### **Vice-Chair**

Mr. Stephen E. Bailey, P.E.  
Electrical Engineer

Mr. John Famularo,  
Roofing Contractor  
Mrs. Shalanda Giles Nelson,  
General Contractor  
Mr. Daniel Rourke  
Master Plumber  
Mr. Gregg D'Atile,  
Mechanical Contractor  
Mr. Ron Burr  
Swimming Pool Contractor  
Mr. John Sims,  
Master Electrician  
Mr. Dennis A. Ulmer  
Consumer Advocate  
Mr. Abbas H. Zackria, CSI  
Architect  
Mr. Robert A. Kamm, P.E.  
Mechanical Engineer

#### **Vacant**

Representative Disabled Community  
Mr. Sergio Pellecer  
Fire Service Professional

### 2020 Alternate Board Members

Mr. Jeff Falkanger  
Architect  
Mr. Steven Feller, P.E.  
Mechanical Engineer  
Mr. Alberto Fernandez,  
General Contractor  
Mr. Robert Taylor  
Fire Service  
Mr. Gary Elzweig, P.E., F.ASCE  
Structural Engineer  
Mr. David Rice, P.E.  
Electrical Engineer  
Mr. James Terry,  
Master Plumber  
Mr. David Tringo,  
Master Electrician  
Mr. William Flett,  
Roofing Contractor

#### **Board Attorney**

Charles M. Kramer, Esq.

#### **Board Administrative Director**

James DiPietro

—ESTABLISHED 1971—

At its meeting of September 10, 2020, the Board approved an interpretation of Retrofit of Windows, Doors, Garage Doors, Shutters and Skylights, for detached one and two family dwellings, and multiple single family dwellings, (townhouses) with common roof height < 30 feet.

1. A Florida Professional Engineer or Architect may modify the buck or fasteners as specified in a Notice of Acceptance. Such modification must be documented with a signed and sealed letter or drawing.

2. To obtain the required design pressure for a specific opening at a specific site, an individual must utilize one of the following and submit documentation as indicated.

- a) A site-specific plan (signed and sealed) by a Florida Professional Engineer or Architect, indicating the location of all retro openings and the required design pressures.
- b) A site-specific plan (not sealed) indicating the location of all retro openings accompanied by a worst-case design pressure chart (signed and sealed) prepared by a Florida P.E. or Architect.
- c) A site-specific plan (not sealed) indicating the location of all openings and indicating the required design pressures based on the Broward County Fenestration Voluntary Wind Load Chart. (see attached chart).

3. Buildings with a (height) > 30 feet or more shall have a site-specific design (signed and sealed) by a Florida Professional Engineer or Architect, indicating the location of all retro openings and the required design pressures for each opening.

NOTE: Generic charts, graphs alone, etc. are not acceptable for buildings above 30 feet.

EFFECTIVE DATE: September 12, 2012  
RE-ISSUED: October 12, 2017  
EFFECTIVE DATE: December 31, 2020

**\*\*\* PLEASE POST AT YOUR PERMIT COUNTER \*\*\***

## Broward County Fenestration Voluntary Wind Load Chart\*


Per ASCE 7-16 Part 1 and FBC (2020) for Retrofitting in Accordance with Formal Interpretation #24

For Detached One-and Two family dwellings and Multiple Single-Family Dwellings (Townhouses) with Mean Roof Height  $\leq 30$  feet

Wind 170 mph (3-second gust) / Exposure C\*\* /  $K_d = 0.85$  /  $K_{zt} = 1.0$  / Pressures are in PSF / Not for use in Coastal (Exposure 'D' areas)

\* Using Allowable Stress Design methodology ( $P = 0.6w$ ) / \*\* Exposure C or D shall be determined according to ASCE 7-16 Section 26.7 (Exposure Categories)

### Roof and Wall Zone Chart Diagrams



Instructions on how to use these Charts: Determine Mean Roof Height,  $h$ , which is top of roof for flat roofs or the mean roof height for pitched roofs. Find your least horizontal dimension for your building, not including a overhang if it occurs. Calculate the value of,  $a$ , = 10% of least horizontal dimension or  $0.4 \cdot h$ , whichever is smaller, but not less than either 4% of least horizontal dimension or 3 feet. If your roof height is less than 30 feet, but not exactly 15, 20, or 25 feet, you will need to go to the next higher roof height. If your Mean Roof Height is higher than 30 feet, these charts do not apply. Review the diagram which illustrate the wall and roof zones and determine the wind zone in which the component is located. Determine the tributary area of the component. If the tributary area falls in between values, use the value of the smaller tributary area. Select the positive and negative wind pressures corresponding to the wall or roof zone where your component is located. Door pressures shown are for the most common door sizes and are worst case for heights  $\leq 30$  Feet.

Wall Pressure For All Roof Types													Garage/Door Pressures			
Mean Roof Height	15 Ft						20 Ft						$\leq 30$ Ft			
Tributary Area	10	20	35	50	100	500	10	20	35	50	100	500	Effective Wind Area		Positive	Negative
	Wall Positive Pressure		Zone 4 Negative Pressure		Zone 5 Negative Pressure		Width		Height							
Mean Roof Height	25 Ft						30 Ft						14	14	35.4	-41.8
Tributary Area	10	20	35	50	100	500	10	20	35	50	100	500	9	7	38.7	-48.3
Wall Positive Pressure	42.3	40.4	38.8	37.8	35.9	31.5	43.9	41.9	40.3	39.3	37.3	32.8	16	7	37.0	-45.0
Zone 4 Negative Pressure	-45.8	-43.9	-42.4	-41.4	-39.5	-35.1	-47.6	-45.7	-44.1	-43.1	-41.1	-36.5	3	7	41.8	-54.6
Zone 5 Negative Pressure	-56.6	-52.8	-49.7	-47.8	-43.9	-35.1	-58.8	-54.7	-51.7	-49.6	-45.7	-36.5	6	7	39.8	-50.6

## SIMPLIFIED ROOF UPLIFT CHART FOR ROOFING APPLICATIONS

This simplified chart represents the worst case wind pressures for the various roof slopes and heights. This chart is based on a Tributary Area = 10 SF which is required for roofing applications. If the roof height is less than 30 feet, but not exactly 15, 20, or 25 feet, you will need to go to the next higher roof height. If your roof height is higher than 30 feet, these charts do not apply. Refer to Roof Chart Diagrams on Page 1 for Roof Zone Locations

### Mean Roof Height = 15 Feet

Flat Roof		Gable Roof 1.51 to 4:12			Gable Roof 4.1 to 6:12		Gable Roof 6.1: to 12:12		Hip Roof 1.51 to 4:12			Hip Roof 4.1 to 6:12	
Positive*	15.4/38.0		Positive	23.2	Positive	23.2	Positive	34.7		Positive	28.3	Positive	28.3
Zone		Zone	Roof	Overhang	Roof	Overhang	Roof	Overhang	Zone	Roof	Overhang	Roof	Overhang
1	-60.5	1, 2e	-70.1	-80.4	-54.0	-64.3	-63.7	-83.6	1	-63.7	-74.0	-50.8	-60.8
1'	-34.8	2n & 2r	-102	-113	-86.2	-96.5	-70.1	-90.1	2e	-89.4	-99.7	-70.1	-79.0
2	-79.8	3e	-102	-132	-86.2	-116	-86.7	-107	2r	-83.0	-93.3	-70.1	-79.0
3*	-109	3r	-122	-151	-102	-128	-70.1	-90.1	3	-89.4	-119	-70.1	-95.3

### Mean Roof Height = 20 Feet

Flat Roof		Gable Roof 1.51 to 4:12			Gable Roof 4.1 to 6:12		Gable Roof 6.1: to 12:12		Hip Roof 1.51 to 4:12			Hip Roof 4.1 to 6:12	
Positive*	16.4/40.3		Positive	24.6	Positive	24.6	Positive	36.9		Positive	30.1	Positive	30.1
Zone		Zone	Roof	Overhang	Roof	Overhang	Roof	Overhang	Zone	Roof	Overhang	Roof	Overhang
1	-64.2	1, 2e	-74.5	-85.4	-57.4	-68.3	-67.7	-88.9	1	-67.6	-78.6	-54.0	-64.6
1'	-36.9	2n & 2r	-109	-120	-91.5	-102	-74.5	-95.7	2e	-95.0	-106	-74.5	-84.0
2	-84.8	3e	-109	-140	-91.5	-123	-92.1	-113	2r	-88.1	-99.1	-74.5	-84.0
3*	-116	3r	-129	-161	-108	-136	-74.5	-95.7	3	-95.0	-126	-74.5	-101

### Mean Roof Height = 25 Feet

Flat Roof		Gable Roof 1.51 to 4:12			Gable Roof 4.1 to 6:12		Gable Roof 6.1: to 12:12		Hip Roof 1.51 to 4:12			Hip Roof 4.1 to 6:12	
Positive*	17.2/42.3		Positive	25.8	Positive	25.8	Positive	38.7		Positive	31.5	Positive	31.5
Zone		Zone	Roof	Overhang	Roof	Overhang	Roof	Overhang	Zone	Roof	Overhang	Roof	Overhang
1	-67.3	1, 2e	-78.1	-89.5	-60.2	-71.6	-70.9	-93.1	1	-70.9	-82.4	-58.6	-67.7
1'	-38.7	2n & 2r	-114	-125	-96	-107	-78.1	-100	2e	-99.6	-111	-78.1	-88.0
2	-88.8	3e	-114	-147	-96	-129	-96.6	-119	2r	-92.4	-104	-78.1	-88.0
3*	-121	3r	-135	-168	-113	-143	-78.1	-100	3	-99.6	-133	-78.1	-106

### Mean Roof Height = 30 Feet

Flat Roof		Gable Roof 1.51 to 4:12			Gable Roof 4.1 to 6:12		Gable Roof 6.1: to 12:12		Hip Roof 1.51 to 4:12			Hip Roof 4.1 to 6:12	
Positive*	17.9/43.9		Positive	26.8	Positive	26.8	Positive	40.2		Positive	32.8	Positive	32.8
Zone		Zone	Roof	Overhang	Roof	Overhang	Roof	Overhang	Zone	Roof	Overhang	Roof	Overhang
1	-70.0	1, 2e	-81.1	-93.1	-62.6	-74.5	-73.7	-96.8	1	-73.7	-85.6	-58.8	-70.4
1'	-40.2	2n & 2r	-118	-130	-99.8	-112	-81.1	-104	2e	-103	-115	-81.1	-91.4
2	-92.3	3e	-118	-153	-99.8	-134	-100	-123	2r	-96.0	-108	-81.1	-91.4
3*	-126	3r	-141	-175	-118	-148	-81.1	-104	3	-103	-138	-81.1	-110

\* If Parapet >= 3 Ft occurs around entire building use the same Zone 2 pressure for Zone 3 and use the higher positive pressure shown