

## ADDENDUM NO. 2

BID TITLE: Weston Data Center Cooling Improvements

BID NO: 2024-02

DATE: March 6, 2024

To All Bidders:

Bidders for the above referenced Bid shall take note of the following changes, additions, deletions, clarifications, etc., to the Bid documents, which shall become a part of and have precedence over anything shown or described otherwise.

### A. CHANGES IN THE BID DOCUMENTS

None.

### B. CLARIFICATIONS

None.

### C. QUESTIONS FROM BIDDERS

Q: Could you please confirm if there are any wind loading requirements for the condensers, and if so, provide the necessary specifications?

A: Provide standard hurricane tie downs, and that is sufficient per the FBC.

### ATTACHMENTS

1. Walk-Through Attendance Log

**END OF ADDENDUM NO. 2**

**All other information remains as originally described in the solicitation.**



**WALK-THROUGH  
SIGN IN SHEET  
WESTON DATA CENTER COOLING IMPROVEMENTS  
Bid No. 2024-02**

**DATE: MARCH 5, 2024 AT 11:00 A.M. LOCATION: STARTING AT CITY HALL**

PRINT NAME	COMPANY NAME	PHONE	EMAIL ADDRESS
Zsuz Krupa	Thermal Concepts	954 328 8229	zkrupa@thermalconcepts.com
MARLON LOPEZ	BURZARD AC	3056998868	INFO@BURZARDAIRFL.COM
Juraj Ursiny	AIS-ACI	954-415-7009	Juraj@advintservices.com
RAYMOND SERRA YUEN	Falcon Electric	813 833 9640	raymond@falconelectric.com
Blaine Byers.	AMSCO	941 234 2197	bbyers@amsco.com
Carlos Zuluaga	INTEG	954 338 9889	czuluaga@integca.com
HECTOR GRACIA	Air-WAYS Mech.	954-330-7244	HG@airwaysmechanical.com

